

Wet Slip Test Certificate

Friday June 10th, 2016

Supplier: Terra Mater Hardwood Floors Pty Ltd (43 Nicholas Drive, Dandenong South, VIC 3175)

Sample Description: Lakewood

Date Tested: May 2016 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: AS/NZS 4586-2004 Appendix A “Slip resistance classification of new pedestrian surface materials – Wet Pendulum Test Method” using a Four S slider

Test Data:

Sample Identification	Wet floor friction result ¹	Classification ² (Standards Australia Handbook 197)
Lakewood	38	P3

¹ Five test average value

² The classifications indicate that the contribution of the floor surfaces to the risk of slipping when wet is moderate



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B. Eng. (Chemical)
Consultant

CV160428